




84 NORTH PLAN



65 NORTH PLAN



66 NORTH PLAN



SECTION 'B-B'

DISCONNECT & REMOVE EXISTING PLUG IN FUSED SWITCHES AND REPLACE WITH PLUG IN CIRCUIT BREAKERS. (SEE BUSWAY SWITCH REPLACEMENT SCHEDULE, THIS DWG). TURN OVER PLUG IN FUSED SWITCHES TO THE PORT AUTHORITY.

SPECIAL OFFSET CABLE TAP BOX IN HUNG CEILING AREA
EXISTING CONDUITS TO REMAIN
RELOCATED 3/4\"/>

84th FLOOR SECTION A-A & PART RISER

EXISTING 1600A BUSWAY TO REMAIN.
REMOVE 1 EXIST PLUG-IN DISC. SWITCH & RE-INSTALL AFTER COMPLETION OF ELEC. CLOSET WORK.

UTILIZE EXISTING BUSWAY FLOOR SUPPORTS.
DISCONNECT & REMOVE EXISTING PLUG IN FUSED SWITCHES AND REPLACE WITH PLUG IN CIRCUIT BREAKERS. (SEE BUSWAY SWITCH REPLACEMENT SCHEDULE, THIS DWG). TURN OVER PLUG IN FUSED SWITCHES TO THE PORT AUTHORITY.

SPECIAL OFFSET CABLE TAP BOX IN HUNG CEILING AREA
CEILING CONSTRUCTION
SHEETROCK
EXISTING DOOR

TRANSITION BOX
1600A, 480/277V ALUMINUM, PAIRED PHASE BUSWAY TO MATCH EXISTING FEDERAL PACIFIC BUSWAY.
EXIST 1600A BUSWAY TO REMAIN (TYP)

65th FLOOR SECTION A-A & PART RISER

BUSWAY SWITCH			
#	EXIST. SW. SIZE	EXIST. FUSE RATING	
66-1	200A	125A	2
66-2	200A	125A	2
65-1	200A	125A	2
85-1	200A	125A	2

NOTES:

1. SEE DRAWING E-1